

Approved Commercial & Industrial Meter Sockets Revision Date May 15, 2010

Grant County PUD Service Area

Amperages		100	200	400	800	100	200	400	800	100	200	400	800	
Phase	Voltages	Service Type	Cooper Beeline (Circle AW)				Milbank				Model # & - Jaws			
			Model # & - Jaws				Model # & - Jaws				Model # & - Jaws			
1Ø	120/240	Underground or Overhead	114TB - 4	124TB - 4	324N - 4 ¹	12145 - 5 ¹			U3548-X - 4 ¹	UC3435-XL - 5 ¹				
3Ø	120/240													
3Ø	120/208		117TB - 7	127TB - 7	121413 - 13 ²	121413 - 13 ²								
3Ø	277/480													

Note ¹ CT metering: Current Transformer metering is required when the ampacity of a 1Ø service entrance exceed 320 amps.

Note ² CT metering: Current Transformer metering is required when the ampacity of a 3Ø service entrance exceed 200 amps.